



**NOTES**

- 1 APRON, WHERE REQUIRED
- 2 DISTANCE FROM HYDRANT TO TOP OR TOE OF SLOPE, MINIMUM 3' REQUIRED.
- 3 WHERE HYDRANT IS NOT PROTECTED BY A VERTICAL FACE CURB, PROTECTIVE POSTS MAY BE REQUIRED BY DISTRICT. SEE STD. DWG. 4-3 FOR DETAILS.
- 4 HYDRANT SHALL BE LOCATED 5' FROM CURB RETURN, 5' MIN. FROM DRIVEWAY, ON PROPERTY LINE EXTENSION, OR AS SHOWN ON PLANS.

LAST DRAWING APPROVAL DATE	VISTA IRRIGATION DISTRICT	PATH: Z:\ENGINEERING\TOM\STDDWGS\4-2.DWG
12 / 02 / 99	FIRE HYDRANT LOCATIONS	REVISED DECEMBER 3, 2003 <i>John A. Amodeo</i> 12/8/03 JOHN AMODEO DATE R C E 31161
		STANDARD DRAWING 4-2