



- ① ALUMINUM LID / FACE MOUNTED LOCK
- ② 3/8" COPPER GOOSE NECK
- ③ 1/2" x 3/8" BRASS VALVE
- ④ ALUMINUM HOUSING
(KORALEEN WATER QUALITY SAMPLING STATION "STATION GUARD" OR APPROVED EQUAL)
- ⑤ PEA GRAVEL 6" BELOW LIP
- ⑥ 2' x 2' CONCRETE PAD
- ⑦ 1/2" COPPER TUBING POSITION IN CENTER OF TEST STAND
- ⑧ STANDARD SIZE METER BOX
- ⑨ STANDARD 1" METER SERVICE
- ⑩ 1 1/4" x 1/2" BRASS BUSHING
- ⑪ 1" LOCKING CURB STOP

NOTE: WATER SAMPLING SITE APPROVED BY DISTRICTS OPERATIONS WATER QUALITY SECTION.

INSTALL CATHODIC PROTECTION PER STD. DWG. 8-14

SEE STANDARD DWG. W-1 FOR DETAILS

REVISIONS	APPROVED	DATE	VISTA IRRIGATION DISTRICT	PATH: (TOM) H:\STDDWGS\1-12.DWG
			WATER QUALITY SAMPLING STATION	<i>John A. Amodeo</i> 12/2/99
				JOHN AMODEO R. C. E. 31161
ACAD		6/96		STANDARD DRAWING 1-12