



NOTE: FITTINGS SHALL BE FLARED END CONNECTIONS FOR 1" COPPER AND SWEAT BY THREADED FOR 2" COPPER.

- ① FULL CIRCLE BODY CLAMP FOR PVC
- ② BRONZE CORPORATION STOP
- ③ TYPE K COPPER (ONE CONTINUOUS PIECE WITHOUT INTERMEDIATE SPLICES)
- ④ BRONZE ANGLE SERVICE STOP
- ⑤ VALVE WELL (SEE STD. DWG. 5-3)
- ⑥ REDWOOD BLOCK AT TOP OF PIPE ZONE
- ⑦ VALVE WELL CAP (SEE STD. DWG. 5-3)
- ⑧ NO. 10 AWA INSULATED COPPER WIRE- CONNECTED TO COPPER TRACER WIRE INSTALLED ALONG NON-METALLIC PIPE.

P
LEGEND ON PLANS

REVISIONS	APPROVED	DATE	VISTA IRRIGATION DISTRICT	PATH: (TOM) H:\STDDWGS\2-2.DWG
			1" & 2" MANUAL AIR RELEASES (TYPE B)	<i>John A. Amodeo</i> 12/2/97
				JOHN AMODEO R. C. E. 31161
ACAD		6/96		STANDARD DRAWING 2-2