



NOTE: 1. CATHODIC PROTECTION REQUIRED PER STD. DWG. 8-14
 2. SILVER SOLDER JOINTS REQUIRED. FITTINGS SHALL BE FLAREDEND CONNECTIONS FOR 1" COPPER CONNECTIONS AND SWEAT BY THREAD FOR 2" COPPER.

REVISIONS	APPROVED	DATE	VISTA IRRIGATION DISTRICT	PATH: (TOM) H:\STDDWGS2-3.DWG
			1" & 2" AIR AND VACUUM VALVES OR COMBINATION AIR RELEASE/ AIR AND VACUUM VALVES	<i>John A. Amodeo</i> 12/2/97
				JOHN AMODEO R. C. E. 31161
ACAD		6/86		STANDARD DRAWING 2-3