



**NOTES**

- 1 FOR TRENCHING IN STREETS SEE STANDARD CONSTRUCTION DETAILS FOR RESURFACING.
- 2 (\*) INDICATES MIN. RELATIVE COMPACTION.
- 3 UNLESS OTHERWISE SHOWN ON PLANS, COVER OVER PIPE SHALL BE 36" TO 42" OR AS DIRECTED BY THE ENGINEER.

REVISIONS	APPROVED	DATE	VISTA IRRIGATION DISTRICT	PATH: (TOM) H:\STDDWGS\5-2.DWG
			<b>PIPE BEDDING AND TRENCH BACKFILL FOR WATER MAINS</b>	<i>John A. Amodeo</i> 12/2/99 JOHN AMODEO                      DATE R. C. E. 31161
				STANDARD DRAWING <b>5-2</b>
ACAD		6/96		