



DETAIL A
NO SCALE

- ① VALVE
- ② 8" PVC C-900 PIPE, CLASS 150
- ③ 8" VALVE WELL CAP WITH 4' SKIRT
- ④ GALVANIZED VALVE CAN INSERT, 20 GAUGE
- ⑤ NO. 10 A.W.G. BARE COPPER WIRE
- ⑥ SUPPORT WITH (2) 2" x 2" x 12" LONG REDWOOD BLOCKS OR THE CONCRETE VALVE BLOCKING.

NOTES

- 1 PROVIDE CLAMP OR FELT TO HOLD PIPE SECTIONS (ITEM 2) TOGETHER DURING BACKFILL
- 2 PIPE SHALL BE SAW OR MACHINE CUT ON EACH END, NO BEVELED OR BELL SECTIONS SHALL BE PERMITTED.
- 3 SEE STD. DWG. 5-5 FOR BLOCKING REQUIREMENTS
- 4 SEE STD. DWG. 5-4 FOR VALVE STEM EXTENSION
- 5 SEE STD. DWG. 5-5 FOR VALVE BLOCKING

REVISIONS	APPROVED	DATE	VISTA IRRIGATION DISTRICT	PATH: (TOM) H:\STDDWGS\5-3.DWG
			VALVE WELL INSTALLATION	<i>John Amodeo</i> 12/2/99
				JOHN AMODEO R. C. E. 31161
ACAD		6/96		STANDARD DRAWING 5-3