



- NOTES: 1 ALL PIPE CROSSING UNDER FLUME SHALL BE INSTALLED IN A 1/4" STEEL CASING JACKED TO MIN. OF 3' FROM EACH SIDE OF THE FLUME AND AT LEAST 2' BELOW THE FLOOR.
- 2 THE ANNULUS BETWEEN THE PIPE AND THE CASING SHALL BE PRESSURE GROUTED WITH SAND-CEMENT GROUT.
- 3 ALL SEWER PIPE, IN ADDITION TO NO. 1 AND NO. 2 ABOVE, MUST BE WELDED STEEL PIPE, 3/16" THICK WITH 1/2" CEMENT LINING AND 1" CEMENT COATING EXTENDING 25' ON EACH SIDE OF THE FLUME CENTERLINE OR ANY SEWER PIPE IN A STEEL CASING 25' FROM EACH SIDE OF THE FLUME CENTERLINE.

REVISIONS	APPROVED	DATE	VISTA IRRIGATION DISTRICT	PATH: (TOM) H:\STD\DWGS\7-7.DWG
			VISTA FLUME AND PIPE CROSSING SEPARATIONS	<i>John Amodeo</i> JOHN AMODEO R. C. E. 31161
				DATE
ACAD		6/96		STANDARD DRAWING 7-7